

FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878

Reference number: EIGA105-FML Issue date: 1-7-2017 Revision date: 1-1-2022 Supersedes version of: 1-7-2017 Version: 5.0

Danger



SECTION 1: Identification of the substance/mixture and of the company/undertaking

1.1. Product identifier

Trade name : FLAMAL 29 SDS no EIGA105-FML Other means of identification Propylene

> CAS-No. : 115-07-1 EC-No. : 204-062-1 EC Index-No. : 601-011-00-9

REACH registration No : 01-2119447103-50

: C3H6 Chemical formula

1.2. Relevant identified uses of the substance or mixture and uses advised against

Relevant identified uses : See the list of identified uses and exposure scenarios in the annex of the safety data sheet.

Perform risk assessment prior to use.

Uses advised against Consumer use.

Uses other than those listed above are not supported, contact your supplier for more

information on other uses.

1.3. Details of the supplier of the safety data sheet

THE NETHERLANDS:

AIR LIQUIDE BV De Witbogt 1 5652 AG Eindhoven the Netherlands-Nederland

BELGIUM:

L'AIR LIQUIDE BELGE S.A./N.V. Avenue de Bourget / Bourgetlaan 44 1130 Bruxelles-Brussel Belgium-Belgique-België

LUXEMBURG:

L'AIR LIQUIDE LUXEMBOURG S.A. ZONE P.E.D.-B.P.20 L-4801 RODANGE Luxemburg

infosafetydatasheet.albv@airliquide.com www.airliquide-benelux.com

1.4. Emergency telephone number

Emergency telephone number : NL: +31 (0)40 250 35 03 / BE: +32 (0)2 431 72 00 / LUX: +352 50 62 63 1



FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878 Reference number: EIGA105-FML

Country	Organisation/Company	Address	Emergency number	Comment
Belgium	Centre Anti-Poisons/Antigifcentrum c/o Hôpital Central de la Base - Reine Astrid	Rue Bruyn 1 1120 Bruxelles/Brussel	+32 70 245 245	Please dial: 070 245 245 for any urgent questions about intoxication (free of charge 24/7), if not accessible, dial: 02 264 96 30 (standard fee)
Luxembourg	Centre Anti-Poisons/Antigifcentrum c/o Hôpital Central de la Base - Reine Astrid	Rue Bruyn 1 1120 Bruxelles/Brussel	+352 8002 5500	Free telephone number with a 24/7 access. Experts answer all urgency questions on dangerous products in French, or German
Netherlands	Nationaal Vergiftigingen Informatie Centrum	Huispostnummer B.00.118 Postbus 85500 3508 GA Utrecht	+31 88 755 80 00	Only for the purpose of informing medical personnel in cases of acute intoxications

SECTION 2: Hazards identification

2.1. Classification of the substance or mixture

Classification according to Regulation (EC) No. 1272/2008 [CLP]

Physical hazards Flammable gases, Category 1A H220
Gases under pressure: Liquefied gas H280

2.2. Label elements

Labelling according to Regulation (EC) No. 1272/2008 [CLP]

Hazard pictograms (CLP) :





GHS02

GHS04

Signal word (CLP) : Danger

Hazard statements (CLP) : H220 - Extremely flammable gas.

H280 - Contains gas under pressure; may explode if heated.

Precautionary statements (CLP)

- Prevention : P210 - Keep away from heat, hot surfaces, sparks, open flames and other ignition sources.

No smoking.

- Response : P377 - Leaking gas fire: Do not extinguish, unless leak can be stopped safely.

P381 - In case of leakage, eliminate all ignition sources.

- Storage : P403 - Store in a well-ventilated place.



FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878 Reference number: EIGA105-FML

2.3. Other hazards

Asphyxiant in high concentrations.

Contact with liquid may cause cold burns/frostbite.

These high concentrations are within the flammability range. The substance/mixture has no endocrine disrupting properties.

SECTION 3: Composition/information on ingredients

3.1. Substances

Name	Product identifier	%	Classification according to Regulation (EC) No. 1272/2008 [CLP]
Propylene	CAS-No.: 115-07-1 EC-No.: 204-062-1 EC Index-No.: 601-011-00-9 REACH registration No: 01-2119447103- 50	100	Flam. Gas 1A, H220 Press. Gas (Liq.), H280

Contains no other components or impurities which will influence the classification of the product.

3.2. Mixtures Not established.

SECTION 4: First aid measures

4.1. Description of first aid measures

- Inhalation : Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep

victim warm and rested. Call a doctor. Perform cardiopulmonary resuscitation if breathing

stopped.

- Skin contact : In case of frostbite spray with water for at least 15 minutes. Apply a sterile dressing. Obtain

medical assistance.

- Eye contact : Immediately flush eyes thoroughly with water for at least 15 minutes.

- Ingestion : Ingestion is not considered a potential route of exposure.

4.2. Most important symptoms and effects, both acute and delayed

In high concentrations may cause asphyxiation. Symptoms may include loss of

mobility/consciousness. Victim may not be aware of asphyxiation.

In low concentrations may cause narcotic effects. Symptoms may include dizziness,

headache, nausea and loss of co-ordination.

See section 11.

4.3. Indication of any immediate medical attention and special treatment needed

None.

SECTION 5: Firefighting measures

5.1. Extinguishing media

- Suitable extinguishing media : Water spray or fog.

Dry powder.
Carbon dioxide.

Shutting off the source of the gas is the preferred method of control.

Be aware of the risk of formation of static electricity with the use of CO2 extinguishers. Do

not use them in places where a flammable atmosphere may be present.

- Unsuitable extinguishing media : Do not use water jet to extinguish.

AIR LIQUIDE BeNeLux Avenue de Bourget / Bourgetlaan 1130 Brussel Belgium, 0032 (0) 2 431 72 00 EU - en



FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878 Reference number: EIGA105-FML

5.2. Special hazards arising from the substance or mixture

Specific hazards : Exposure to fire may cause containers to rupture/explode.

Hazardous combustion products : Carbon monoxide.

5.3. Advice for firefighters

Specific methods : Use fire control measures appropriate for the surrounding fire. Exposure to fire and heat

radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering

sewers and drainage systems. If possible, stop flow of product.

Use water spray or fog to knock down fire fumes if possible.

Do not extinguish a leaking gas flame unless absolutely necessary. Spontaneous/explosive

re-ignition may occur. Extinguish any other fire.

Move containers away from the fire area if this can be done without risk.

Special protective equipment for fire fighters : In confined space use self-contained breathing apparatus.

Standard protective clothing and equipment (Self Contained Breathing Apparatus) for fire

fighters.

Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full

face mask.

Standard EN 469 - Protective clothing for firefighters. Standard - EN 659: Protective gloves

for firefighters.

SECTION 6: Accidental release measures

6.1. Personal precautions, protective equipment and emergency procedures

For non-emergency personnel : Act in accordance with local emergency plan.

Try to stop release. Evacuate area.

Eliminate ignition sources. Ensure adequate air ventilation.

Prevent from entering sewers, basements and workpits, or any place where its

accumulation can be dangerous.

Stay upwind.

See section 8 of the SDS for more information on personal protective equipment

For emergency responders : Monitor concentration of released product.

Consider the risk of potentially explosive atmospheres.

Wear self-contained breathing apparatus when entering area unless atmosphere is proved

to be safe.

See section 5.3 of the SDS for more information.

6.2. Environmental precautions

Try to stop release.

6.3. Methods and material for containment and cleaning up

Ventilate area.

6.4. Reference to other sections

See also sections 8 and 13.

EU - en



FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878 Reference number: EIGA105-FML

SECTION 7: Handling and storage

7.1. Precautions for safe handling

Safe handling of the gas receptacle

Safe use of the product

Do not breathe gas.

Avoid release of product into work area.

The product must be handled in accordance with good industrial hygiene and safety procedures.

Only experienced and properly instructed persons should handle gases under pressure.

Consider pressure relief device(s) in gas installations.

Ensure the complete gas system was (or is regularily) checked for leaks before use.

Do not smoke while handling product.

Use only properly specified equipment which is suitable for this product, its supply pressure and temperature. Contact your gas supplier if in doubt.

Avoid suck back of water, acid and alkalis.

Assess the risk of potentially explosive atmospheres and the need for explosion-proof equipment.

Purge air from system before introducing gas.

Take precautionary measures against static discharge.

Keep away from ignition sources (including static discharges).

Consider the use of only non-sparking tools.

Ensure equipment is adequately earthed.

: Refer to supplier's container handling instructions.

Do not allow backfeed into the container.

Protect containers from physical damage; do not drag, roll, slide or drop.

When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.)

designed to transport cylinders.

Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use.

If user experiences any difficulty operating valve discontinue use and contact supplier.

Never attempt to repair or modify container valves or safety relief devices.

Damaged valves should be reported immediately to the supplier.

Keep container valve outlets clean and free from contaminants particularly oil and water. Replace valve outlet caps or plugs and container caps where supplied as soon as container

is disconnected from equipment.

Close container valve after each use and when empty, even if still connected to equipment.

Never attempt to transfer gases from one cylinder/container to another.

Never use direct flame or electrical heating devices to raise the pressure of a container.

Do not remove or deface labels provided by the supplier for the identification of the content $% \left(1\right) =\left(1\right) \left(1\right) \left$

of the container.

Suck back of water into the container must be prevented.

Open valve slowly to avoid pressure shock.

7.2. Conditions for safe storage, including any incompatibilities

Observe all regulations and local requirements regarding storage of containers.

Containers should not be stored in conditions likely to encourage corrosion.

Container valve guards or caps should be in place.

Containers should be stored in the vertical position and properly secured to prevent them from falling over.

Stored containers should be periodically checked for general condition and leakage.

Keep container below 50°C in a well ventilated place.

Store containers in location free from fire risk and away from sources of heat and ignition.

5/11

Keep away from combustible materials.

Segregate from oxidant gases and other oxidants in store.

All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.

7.3. Specific end use(s)

None.

AIR LIQUIDE BeNeLux EU - en



FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878 Reference number: EIGA105-FML

SECTION 8: Exposure controls/personal protection

8.1. Control parameters

DNEL (Derived-No Effect Level) : None established.

FLAMAL 29 (115-07-1)		
PNEC: Predicted no effect concentration		
Aqua (freshwater)	1,38 mg/l	
Aqua (marine water)	1,38 mg/l	

8.2. Exposure controls

8.2.1. Appropriate engineering controls

Provide adequate general and local exhaust ventilation.

Product to be handled in a closed system.

Systems under pressure should be regularily checked for leakages.

Ensure exposure is below occupational exposure limits (where available).

Gas detectors should be used when flammable gases/vapours may be released.

Consider the use of a work permit system e.g. for maintenance activities.

8.2.2. Individual protection measures, e.g. personal protective equipment

A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk.

The following recommendations should be considered:

PPE compliant to the recommended EN/ISO standards should be selected.

Wear goggles when transfilling or breaking transfer connections. Standard EN 166 - Personal eye-protection - specifications.

Skin protection

· Eye/face protection

- Hand protection : Wear working gloves when handling gas containers.

Standard EN 388 - Protective gloves against mechanical risk, performance level 1 or higher.

Wear cold insulating gloves when transfilling or breaking transfer connections.

Standard EN 511 - Cold insulating gloves.

- Other : Consider the use of flame resistant anti-static safety clothing.

Standard EN ISO 14116 - Limited flame spread materials. Standard EN 1149-5 - Protective clothing: Electrostatic properties.

Wear safety shoes while handling containers.

Standard EN ISO 20345 - Personal protective equipment - Safety footwear.

Respiratory protection
 Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with full

face mask.

Self contained breathing apparatus (SCBA) or positive pressure airline with mask are to be

used in oxygen-deficient atmospheres.

Self contained breathing apparatus is recommended, where unknown exposure may be

expected, e.g. during maintenance activities on installation systems.

• Thermal hazards : None in addition to the above sections.

8.2.3. Environmental exposure controls

Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for specific methods for waste gas treatment.

SECTION 9: Physical and chemical properties

9.1. Information on basic physical and chemical properties

Appearance

- Physical state at 20°C / 101.3kPa- Colour: Gas- Colourless.

Odour : Stenchant often added. Sweetish. Poor warning properties at low concentrations.

Odour threshold is subjective and inadequate to warn of overexposure.

AIR LIQUIDE BeNeLux Avenue de Bourget / Bourgetlaan 1130 Brussel Belgium, 0032 (0) 2 431 72 00 EU - en



FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878 Reference number: EIGA105-FML

pH : Not applicable for gases and gas mixtures.

Melting point / Freezing point : -185 °C Boiling point : -47,7 °C

Flash point : Not applicable for gases and gas mixtures.

Flammability : Extremely flammable gas.

Explosive limits : 1,8 – 11,2 vol %
Lower explosive limit (LEL) : Not available
Upper explosive limit (UEL) : Not available
Vapour pressure [20°C] : 10,2 bar(a)
Vapour pressure [50°C] : 20,5 bar(a)
Density : Not applicable
Vapour density : Not applicable.

Relative density, liquid (water=1) : 0,6
Relative density, gas (air=1) : 1,5
Water solubility : 384 mg/l
Partition coefficient n-octanol/water (Log Kow) : 1,77
Auto-ignition temperature : 485 °C
Decomposition temperature : Not applicable.

Viscosity, kinematic : No reliable data available.

Particle characteristics : Not applicable

9.2. Other information

9.2.1. Information with regard to physical hazard classes

Oxidising properties : No oxidising properties.

Critical temperature [°C] : 92,4 °C

9.2.2. Other safety characteristics

Molar mass : 42 g/mol

Other data : Gas/vapour heavier than air. May accumulate in confined spaces, particularly at or below

ground level.

SECTION 10: Stability and reactivity

10.1. Reactivity

No reactivity hazard other than the effects described in sub-sections below.

10.2. Chemical stability

Stable under normal conditions.

10.3. Possibility of hazardous reactions

Can form explosive mixture with air. May react violently with oxidants.

10.4. Conditions to avoid

Keep away from heat/sparks/open flames/hot surfaces. - No smoking.

Avoid moisture in installation systems.

10.5. Incompatible materials

Air, Oxidisers.

For additional information on compatibility refer to ISO 11114.

10.6. Hazardous decomposition products

Under normal conditions of storage and use, hazardous decomposition products should not

be produced.



FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878 Reference number: EIGA105-FML

SECTION 11: Toxicological information

11.1. Information on hazard classes as defined in Regulation (EC) No 1272/2008

Acute toxicity : Toxicological effects not expected from this product if occupational exposure limit values are

not exceeded.

 Skin corrosion/irritation
 : No known effects from this product.

 Serious eye damage/irritation
 : No known effects from this product.

 Respiratory or skin sensitisation
 : No known effects from this product.

 Germ cell mutagenicity
 : No known effects from this product.

 Carcinogenicity
 : No known effects from this product.

Carcinogenicity : No known effects from this product.

Toxic for reproduction : Fertility : No known effects from this product.

Toxic for reproduction : unborn child : No known effects from this product.

STOT-single exposure: No known effects from this product.STOT-repeated exposure: No known effects from this product.

Aspiration hazard : Not applicable for gases and gas mixtures.

11.2. Information on other hazards

No additional information available

SECTION 12: Ecological information

12.1. Toxicity

Assessment : Classification criteria are not met.

 EC50 48h - Daphnia magna [mg/l]
 : 28,2 mg/l

 EC50 72h - Algae [mg/l]
 : No data available.

 LC50 96 h - Fish [mg/l]
 : 51,7 mg/l

12.2. Persistence and degradability

Assessment : The substance is readily biodegradable. Unlikely to persist.

12.3. Bioaccumulative potential

Assessment : Not expected to bioaccumulate due to the low log Kow (log Kow < 4).

See section 9.

12.4. Mobility in soil

Assessment : Because of its high volatility, the product is unlikely to cause ground or water pollution.

Partition into soil is unlikely.

12.5. Results of PBT and vPvB assessment

Assessment : Not classified as PBT or vPvB.

12.6. Endocrine disrupting properties

No additional information available

12.7. Other adverse effects

Other adverse effects : No known effects from this product. Effect on the ozone layer : No effect on the ozone layer.

Global warming potential [CO2=1] :

Effect on global warming : When discharged in large quantities may contribute to the greenhouse effect.

Contains greenhouse gas(es).

EU - en



FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878 Reference number: EIGA105-FML

SECTION 13: Disposal considerations

13.1. Waste treatment methods

Contact supplier if guidance is required.

Do not discharge into areas where there is a risk of forming an explosive mixture with air.

Waste gas should be flared through a suitable burner with flash back arrestor.

Do not discharge into any place where its accumulation could be dangerous.

Ensure that the emission levels from local regulations or operating permits are not

exceeded.

Refer to the EIGA code of practice Doc.30 "Disposal of Gases", downloadable at

http://www.eiga.org for more guidance on suitable disposal methods.

Return unused product in original container to supplier.

List of hazardous waste codes (from Commission Decision 2000/532/EC as amended)

16 05 04 *: Gases in pressure containers (including halons) containing hazardous

substances.

13.2. Additional information

External treatment and disposal of waste should comply with applicable local and/or national regulations.

SECTION 14: Transport information

14.1. UN number or ID number

In accordance with ADR / RID / IMDG / IATA / ADN

UN-No. : 1077

14.2. UN proper shipping name

Transport by road/rail (ADR/RID) : PROPYLENE
Transport by air (ICAO-TI / IATA-DGR) : Propylene
Transport by sea (IMDG) : PROPYLENE

14.3. Transport hazard class(es)

Labelling

2

2.1: Flammable gases.

Transport by road/rail (ADR/RID)

Class : 2
Classification code : 2F
Hazard identification number : 23

Tunnel Restriction : B/D - Tank carriage : Passage forbidden through tunnels of category B, C, D and E. Other

carriage: Passage forbidden through tunnels of category D and E

Transport by air (ICAO-TI / IATA-DGR)

Class / Div. (Sub. risk(s)) : 2.1

Transport by sea (IMDG)

Class / Div. (Sub. risk(s)) : 2.1
Emergency Schedule (EmS) - Fire : F-D
Emergency Schedule (EmS) - Spillage : S-U

14.4. Packing group

Transport by road/rail (ADR/RID) : Not established.

Transport by air (ICAO-TI / IATA-DGR) : Not established.

Transport by sea (IMDG) : Not established.

14.5. Environmental hazards

Transport by road/rail (ADR/RID) : None.

Transport by air (ICAO-TI / IATA-DGR) : None.

AIR LIQUIDE BeNeLux Avenue de Bourget / Bourgetlaan 1130 Brussel Belgium, 0032 (0) 2 431 72 00 EU - en



FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878 Reference number: EIGA105-FML

Transport by sea (IMDG) : None.

14.6. Special precautions for user

Packing Instruction(s)

Transport by road/rail (ADR/RID) : P200

Transport by air (ICAO-TI / IATA-DGR)

Passenger and Cargo Aircraft : Forbidden.
Cargo Aircraft only : 200.
Transport by sea (IMDG) : P200

Special transport precautions : Avoid transport on vehicles where the load space is not separated from the driver's

compartment.

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in

the event of an accident or an emergency.
Before transporting product containers:
- Ensure there is adequate ventilation.
- Ensure that containers are firmly secured.
- Ensure valve is closed and not leaking.

- Ensure valve outlet cap nut or plug (where provided) is correctly fitted.

- Ensure valve protection device (where provided) is correctly fitted.

14.7. Maritime transport in bulk according to IMO instruments

Not applicable.

SECTION 15: Regulatory information

15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture

EU-Regulations

Restrictions on use : None. Seveso Directive : 2012/18/EU (Seveso III) : Listed.

National regulations

Regulatory reference : Ensure all national/local regulations are observed.

15.2. Chemical safety assessment

A CSA has been carried out.

SECTION 16: Other information

Indication of changes : Revised safety data sheet in accordance with commission regulation (EU) No 453/2010.

Section	Changed item	Change	Comments
	Supersedes	Modified	
	Revision date	Modified	
	Relevant identified uses	Modified	
2.3	Other hazards which do not result in classification	Modified	
8.2	Respiratory protection	Modified	
9.1	Oxidising properties	Modified	
9.1	Flash point	Removed	
10.2	Chemical stability	Modified	



FLAMAL 29

according to the REACH Regulation (EC) 1907/2006 amended by Regulation (EU) 2020/878 Reference number: EIGA105-FML

Abbreviations and acronyms

: ATE - Acute Toxicity Estimate

CLP - Classification Labelling Packaging Regulation; Regulation (EC) No 1272/2008 REACH - Registration, Evaluation, Authorisation and Restriction of Chemicals Regulation (EC) No 1907/2006

EINECS - European Inventory of Existing Commercial Chemical Substances

CAS# - Chemical Abstract Service number PPE - Personal Protection Equipment

LC50 - Lethal Concentration to 50 % of a test population

RMM - Risk Management Measures

PBT - Persistent, Bioaccumulative and Toxic vPvB - Very Persistent and Very Bioaccumulative

STOT- SE: Specific Target Organ Toxicity - Single Exposure

CSA - Chemical Safety Assessment

EN - European Standard UN - United Nations

ADR - European Agreement concerning the International Carriage of Dangerous Goods by

Road

IATA - International Air Transport Association

IMDG code - International Maritime Dangerous Goods

RID - Regulations concerning the International Carriage of Dangerous Goods by Rail

WGK - Water Hazard Class

STOT - RE: Specific Target Organ Toxicity - Repeated Exposure

UFI: Unique Formula Identifier

: Ensure operators understand the flammability hazard.

Classification in accordance with the procedures and calculation methods of Regulation

(EC) 1272/2008 (CLP).

Key literature references and sources of data are maintained in EIGA doc 169 : 'Classification and Labelling Guide', downloadable at http://www.Eiga.eu .

Full text of H- and EUH-statements		
Flam. Gas 1A	Flammable gases, Category 1A	
H220	Extremely flammable gas.	
H280	Contains gas under pressure; may explode if heated.	
Press. Gas (Liq.)	Gases under pressure : Liquefied gas	

DISCLAIMER OF LIABILITY

Training advice Further information

: Before using this product in any new process or experiment, a thorough material compatibility and safety study should be carried out.

Details given in this document are believed to be correct at the time of going to press. Whilst proper care has been taken in the preparation of this document, no liability for injury or damage resulting from its use can be accepted.

End of document