

Page : 1/11 Revised edition no : 5.0

Revision date : 2023-01-19

Supersedes version of : 2021-06-17 NOAL_0067B

Hydrogen

Country : DK / Language : EN

SECTION 1: Identification of the sub	stance/mixture and of the company/undertaking
1.1. Product identifier	
Trade name SDS no Other means of identification	 Hydrogen, Hydrogen N25 Tubetrailer NOAL_0067B Hydrogen CAS-No. 1333-74-0 EC-No. 215-605-7 EC Index-No. 001-001-00-9
REACH registration No	: Listed in Annex IV / V REACH, exempted from registration.
Chemical formula	: H2
1.2. Relevant identified uses of the substance	e or mixture and uses advised against
Relevant identified uses	 Industrial and professional uses. Perform risk assessment prior to use. Test gas/Calibration gas. Laboratory use. Chemical reaction / Synthesis. Use as a fuel. Shield gas for welding processes. Contact supplier for more information on uses.
Uses advised against	 Consumer use. Uses other than those listed above are not supported, contact your supplier for more information on other uses.
1.3. Details of the supplier of the safety data s	sheet
Company identification Supplier AIR LIQUIDE Denmark A/S Høje Taastrupvej 42 2630 Taastrup - DENMARK T +45 76 25 25 25 info.denmark@airliquide.com	
E-Mail address (competent person)	: eunordic-sds@airliquide.com
<u>1.4. Emergency telephone number</u> Emergency telephone number	: 112 (24 / 7) Availability

SECTION 2: Hazards identification

2.1. Classification of the substance or mixture Classification according to Regulation (EC) No. 1272/2008 [CLP]

Physical hazards	Flammable gases, Category 1A	H220
	Gases under pressure : Refrigerated liquefied gas	H281



Page : 2/11 Revised edition no : 5.0

Revision date : 2023-01-19 Supersedes version of : 2021-06-17

Hydrogen

NOAL_0067B Country : DK / Language : EN

2.2. Label elements

Labelling according to Regulation (EC) No. 127	2/2008 [CLP]
Hazard pictograms (CLP)	
	GHS02 GHS04
Signal word (CLP)	: Danger
Hazard statements (CLP)	: H220 - Extremely flammable gas.
	H281 - Contains refrigerated gas; may cause cryogenic burns or injury.
Precautionary statements (CLP)	
- Prevention	: P282 - Wear cold insulating gloves and either face shield or eye protection. cold insulating gloves, face shield, eye protection.
	P210 - Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No smoking.
	P282 - Wear cold insulating gloves and either face shield or eye protection.
	P210 - Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No smoking.
- Response	: P336+P315 - Thaw frosted parts with lukewarm water. Do not rub affected area. Get immediate medical advice.
	P336+P315 - Thaw frosted parts with lukewarm water. Do not rub affected area. Get immediate medical advice/attention.
	P377 - Leaking gas fire: Do not extinguish, unless leak can be stopped safely.
	P381 - In case of leakage, eliminate all ignition sources.
	P381 - In case of leakage, eliminate all ignition sources.
- Storage	: P403 - Store in a well-ventilated place.
2.3. Other hazards	
	None.
	Not classified as PBT or vPvB.
	The substance/mixture has no endocrine disrupting properties.

SECTION 3: Composition/information on ingredients

3.1. Substances

Name	Product identifier	Composition [V- %]:	Classification according to Regulation (EC) No. 1272/2008 [CLP]
Hydrogen	CAS-No.: 1333-74-0 EC-No.: 215-605-7 EC Index-No.: 001-001-00-9 REACH registration No: *1	100	Flam. Gas 1A, H220 Press. Gas (Ref. Liq.), H281

Contains no other components or impurities which will influence the classification of the product.

*1: Listed in Annex IV / V REACH, exempted from registration.

*3: Registration not required: Substance manufactured or imported < 1t/y.

Air Liquide

SAFETY DATA SHEET

Page : 3/11

Revised edition no : 5.0

Revision date : 2023-01-19 Supersedes version of : 2021-06-17

Hydrogen

NOAL_0067B Country : DK / Language : EN

3.2. Mixtures

Not established.

4.1. Description of first aid measures	
- Inhalation	: Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep victim warm and rested. Call a doctor. Perform cardiopulmonary resuscitation if breathing
- Skin contact	stopped. : In case of frostbite spray with water for at least 15 minutes. Apply a sterile dressing. Obtair
- Skill Collact	medical assistance.
- Eye contact - Ingestion	 Immediately flush eyes thoroughly with water for at least 15 minutes. Ingestion is not considered a potential route of exposure.
4.2. Most important symptoms and effects, bo	oth acute and delayed
	See section 11.
4.3. Indication of any immediate medical atten	ntion and special treatment needed
	None.
SECTION 5: Firefighting measures	
5.1. Extinguishing media	
- Suitable extinguishing media	: Water spray or fog.
- Unsuitable extinguishing media	Dry powder. : Carbon dioxide.
	Do not use water jet to extinguish.
5.2. Special hazards arising from the substand	<u>ce or mixture</u>
Specific hazards	: Exposure to fire may cause containers to rupture/explode.
Hazardous combustion products	: None.
5.3. Advice for firefighters	
Specific methods	 Use fire control measures appropriate for the surrounding fire. Exposure to fire and heat radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering sewers and drainage systems. If possible, stop flow of product. Use water spray or fog to knock down fire fumes if possible. If leaking do not spray water onto container. Water surrounding area (from protected position) to contain fire. Do not extinguish a leaking gas flame unless absolutely necessary. Spontaneous/explosive re-ignition may occur. Extinguish any other fire. Move containers away from the fire area if this can be done without risk.
Special protective equipment for fire fighters	 In confined space use self-contained breathing apparatus. Standard protective clothing and equipment (Self Contained Breathing Apparatus) for fire fighters. Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with fu face mask. Standard EN 469 - Protective clothing for firefighters. Standard - EN 659: Protective gloves for firefighters.

Air Liquide

SAFETY DATA SHEET

Page : 4/11

Revised edition no : 5.0

Revision date : 2023-01-19 Supersedes version of : 2021-06-17

Hydrogen

NOAL_0067B Country : DK / Language : EN

SECTION 6: Accidental release measures

6.1. Personal precautions, protective equipment a	nd emergency procedures
For non-emergency personnel	: Act in accordance with local emergency plan. Use protective clothing. Stay upwind.
For emergency responders	See section 8 of the SDS for more information on personal protective equipment : See section 5.3 of the SDS for more information.
6.2. Environmental precautions	
	Try to stop release. Liquid spillages can cause embrittlement of structural materials.
6.3. Methods and material for containment and cle	paning up
	Ventilate area.
6.4. Reference to other sections	See also sections 8 and 13.

SECTION 7: Handling and storage

7.1. Precautions for safe handling	
7.1. Precautions for safe handling Safe use of the product	 Do not breathe gas. Avoid release of product into atmosphere. The product must be handled in accordance with good industrial hygiene and safety procedures. Only experienced and properly instructed persons should handle gases under pressure. Consider pressure relief device(s) in gas installations. Ensure the complete gas system was (or is regularily) checked for leaks before use. Do not smoke while handling product. Use only properly specified equipment which is suitable for this product, its supply pressure and temperature. Contact your gas supplier if in doubt. Avoid suck back of water, acid and alkalis. Assess the risk of potentially explosive atmospheres and the need for explosion-proof equipment. Purge air from system before introducing gas. Take precautionary measures against static discharge. Keep away from ignition sources (including static discharges).
	Consider the use of only non-sparking tools. Ensure equipment is adequately earthed.

Product of the construction of the		SAFETY DATA SHEET	Page : 5/11
A specific end use(s) A specific end use(s) A specific end use(s)	Airliquido		Revised edition no : 5.0
Hydrogen NOAL_0067B Safe handling of the gas receptade Refer to supplier's container handling instructions. Do not allow backfeed into the container. Protect containers from physical damage; do not drag, roll, slide or drop. When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders. Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use. If user experiences any difficulty operating valve discontinue use and contact supplier. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier. Keep container valve outlets clean and free from contaminants particularly oil and water. Replace valve outlet caps or plugs and container caps where supplied as soon as containe is disconnected from equipment. Close container valve outlet caps or plugs and container to another. Never use direct flame or electrical heating devices to raise the pressure of a container. Do not remove or deface labels provided by the supplier for the identification of the container. Suck back of water into the container must be prevented. Open valve slowly to avoid pressure shock. *2.2 Conditions for safe storage, including any incompatibilities Observe all regulations and local requirements regarding storage of containers. Containers should be stored in the vertical position and properly secured to prevent them from falling over. Store containers should be stored in the vertical position and properly secured to prevent them from falling over. Store containers should be stored in the vertical position and properly secured to prevent them from falling over. Stored containers who way from comutual by avert place. Ale			Revision date : 2023-01-19
Country : DK / Language : EN Country : DK / Language : EN Do not allow backfeed into the container. Protect containers from physical damage; do not drag, roll, slide or drop. When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders. Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use. If user experiences any difficult operating valve discontinue use and contact supplier. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier. Keep container valve outlet caps or plugs and containers spatial and water. Replace valve outlet caps or plugs and container caps where supplied as soon as containe is disconnected from equipment. Close container valve after each use and when empty, even if still connected to equipment. Never attempt to transfer gases from one cylinder/container to another. Never attempt to avoid pressure should be the supplier for the identification of the container. Do not remove or deface labels provided by the supplier for the identification of the container. Suck back of water into the container must be prevented. Open valve slowly to avoid pressure shock. /2. Conditions for safe storage, including any incompatibilities Deserve all regulations and local requirements regarding storage of containers. Container valve guards or caps should be in place. Containers should be stored in the vertical position and properly secured to prevent them from faling over. Store container biolow 50°C in a well ventibuted place. Store container biolow 50°C in a well ventibuted place. Store container biolow 50°C in a well ventibuted place. Store container biolow 50°C in a well ventibuted place. All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.			Supersedes version of : 2021-06-17
Country : DK / Language : EN Contailer shandling instructions. Do not allow backfeed into the container. Protect containers from physical damage; do not drag, roll, slide or drop. When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders. Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use. If user experiences any difficulty operating valve discontinue use and contact supplier. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier devices. Damaged valves should be reported immediately to the supplier devices. Damaged valves should be reported immediately to the supplier devices. Damaged valves after each use and when empty, even if still connected to equipment. Close container valve outlet caps or plugs and container caps where supplied as soon as containe is disconnected from equipment. Never attempt to transfer gases from one cylinder/container to another. Never attempt to transfer gases from one cylinder/container to another. Never use direct finame or electrical heating devices to raise the pressure of a container. Do not remove or deface labels provided by the supplier for the identification of the container. Suck back of water into the container must be prevented. Open valve slowly to avoid pressure shock. /// Conditions for safe storage, including any incompatibilities Deserve all regulations and local requirements regarding storage of containers. Containers should not be stored in conditions likely to encourage corrosion. Container valve guards or caps should be in place. Containers should be stored in the vertical position and properly secured to prevent them from falling over. Store containers bould be stored in the vertical position and properly secured to prevent the		Hydrogen	NOAL_0067B
Do not allow backfeed into the container. Protect containers from physical damage: do not drag, roll, slide or drop. When moving cylinders. Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use. If user experiences any difficulty operating valve discontinue use and contact supplier. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier. Keep container valve outlets clean and free from contaminants particularly oil and water. Replace valve outlet caps or plugs and container caps where supplied as soon as containe is disconnected from equipment. Close container valve after each use and when empty, even if still connected to equipment. Never attempt to transfer gases from one cylinder/container to another. Never use direct flame or electrical heating devices to raise the pressure of a container. Do not remove or deface labels provided by the supplier for the identification of the content of the container. Suck back of water into the container must be prevented. Open valve slowly to avoid pressure shock. 2.2. Conditions for safe storage, including any incompatibilities Diserve al legulations and local requirements regarding storage of containers. Containers should be tored in conditions likely to encourage corrosion. Containers should be stored in the vertical position and properly secured to prevent them from falling over. Stored containers should be periodically checked for general condition and leakage. Keep containers in location free from fire risk and away from sources of heat and ignition. Keep away from combustible materials. Segregate from oxidant gases and other oxidants in store. All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.			Country : DK / Language : EN
Observe all regulations and local requirements regarding storage of containers. Containers should not be stored in conditions likely to encourage corrosion. Container valve guards or caps should be in place. Containers should be stored in the vertical position and properly secured to prevent them from falling over. Stored containers should be periodically checked for general condition and leakage. Keep container below 50°C in a well ventilated place. Store containers in location free from fire risk and away from sources of heat and ignition. Keep away from combustible materials. Segregate from oxidant gases and other oxidants in store. All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.	Safe handling of the gas receptacle	Do not allow backfeed into the container. Protect containers from physical damage; do not dra When moving cylinders, even for short distances, us designed to transport cylinders. Leave valve protection caps in place until the contai wall or bench or placed in a container stand and is r If user experiences any difficulty operating valve dis Never attempt to repair or modify container valves of Damaged valves should be reported immediately to Keep container valve outlets clean and free from co Replace valve outlet caps or plugs and container ca is disconnected from equipment. Close container valve after each use and when emp Never attempt to transfer gases from one cylinder/c Never use direct flame or electrical heating devices Do not remove or deface labels provided by the sup of the container.	se a cart (trolley, hand truck, etc.) iner has been secured against either a ready for use. scontinue use and contact supplier. or safety relief devices. the supplier. intaminants particularly oil and water. aps where supplied as soon as container oty, even if still connected to equipment. iontainer to another. to raise the pressure of a container. oplier for the identification of the content
Containers should not be stored in conditions likely to encourage corrosion. Container valve guards or caps should be in place. Containers should be stored in the vertical position and properly secured to prevent them from falling over. Stored containers should be periodically checked for general condition and leakage. Keep container below 50°C in a well ventilated place. Store containers in location free from fire risk and away from sources of heat and ignition. Keep away from combustible materials. Segregate from oxidant gases and other oxidants in store. All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.	7.2. Conditions for safe storage, inclu	uding any incompatibilities	
		Containers should not be stored in conditions likely Container valve guards or caps should be in place. Containers should be stored in the vertical position from falling over. Stored containers should be periodically checked for Keep container below 50°C in a well ventilated plac Store containers in location free from fire risk and a Keep away from combustible materials. Segregate from oxidant gases and other oxidants in All electrical equipment in the storage areas should	to encourage corrosion. and properly secured to prevent them or general condition and leakage. e. way from sources of heat and ignition.
Nono	7.3. Specific end use(s)		
		None	

SECTION 8: Exposure controls/personal protection	
8.1. Control parameters	
OEL (Occupational Exposure Limits)	: None available.
DNEL (Derived-No Effect Level)	: None available.
PNEC (Predicted No-Effect Concentration)	: None available.
8.2. Exposure controls	
8.2.1. Appropriate engineering controls	
	Provide adequate general and local exhaust ventilation.
	Product to be handled in a closed system.
	Systems under pressure should be regularily checked for leakages.
	Gas detectors should be used when flammable gases/vapours may be released.
	Consider the use of a work permit system e.g. for maintenance activities.

O Air Liquide

SAFETY DATA SHEET

Page : 6/11

Revised edition no : 5.0 Revision date : 2023-01-19

Supersedes version of : 2021-06-17 **NOAL 0067B**

Country : DK / Language : EN

Hydrogen

8.2.2. Individual protection measures, e.g. personal protective equipment

	A risk assessment should be conducted and documented in each work area to assess the risks related to the use of the product and to select the PPE that matches the relevant risk. The following recommendations should be considered: PPE compliant to the recommended EN/ISO standards should be selected.
Eye/face protection	 Wear goggles and a face shield when transfilling or breaking transfer connections. Standard EN 166 - Personal eye-protection - specifications.
Skin protection	
- Hand protection	: Wear working gloves when handling gas containers.
	Standard EN 388 - Protective gloves against mechanical risk, performance level 1 or higher. Wear cold insulating gloves when transfilling or breaking transfer connections. Standard EN 511 - Cold insulating gloves.
- Other	 Consider the use of flame resistant anti-static safety clothing. Standard EN ISO 14116 - Limited flame spread materials. Standard EN 1149-5 - Protective clothing: Electrostatic properties. Wear safety shoes while handling containers. Standard EN ISO 20345 - Personal protective equipment - Safety footwear.
Respiratory protection	 Self contained breathing apparatus is recommended, where unknown exposure may be expected, e.g. during maintenance activities on installation systems. None necessary.
Thermal hazards	None in addition to the above sections.
8.2.3. Environmental exposure controls	
	Refer to local regulations for restriction of emissions to the atmosphere. See section 13 for specific methods for waste gas treatment.

SECTION 9: Physical and chemical properties

9.1. Information on basic physical and chemical properties

Appearance	
- Physical state at 20°C / 101.3kPa	: Liquid
- Colour	: Colourless.
Odour	: Odourless.
	Odour threshold is subjective and inadequate to warn of overexposure.
pH	: Not applicable for gases and gas mixtures.
Melting point / Freezing point	: -259 °C
	-259 °C
Boiling point	: -253 °C
Flash point	: Not applicable for gases and gas mixtures.
Flammability	: Extremely flammable gas
Explosive limits	: 4 – 77 vol %
Lower explosion limit	: Not available
Upper explosion limit	: Not available
Vapour pressure [20°C]	: Not applicable.
Vapour pressure [50°C]	: Not applicable.
Density	: Not available
Vapour density	: Not applicable for gases and gas mixtures.
Relative density, liquid (water=1)	: 0.07
Relative density, gas (air=1)	: 0.07
Water solubility	: 1.6 mg/l
Partition coefficient n-octanol/water (Log Kow)	: Not applicable for inorganic products.
Auto-ignition temperature	: 560 °C
Decomposition temperature	: Not applicable.
Viscosity, kinematic	: No reliable data available.
Particle characteristics	: Not applicable for gases and gas mixtures.



Page : 7/11

Revised edition no : 5.0 Revision date : 2023-01-19

Supersedes version of : 2021-06-17

Hydrogen

NOAL_0067B Country : DK / Language : EN

9.2. Other information

9.2.1. Information with regard to physical hazar	d classes
Explosive properties	: Not applicable.
Oxidising properties Tci	: Not applicable. : 5.5 %
Critical temperature [°C]	: -240 °C
9.2.2. Other safety characteristics	
9.2.2. Other safety characteristics Molar mass	: 2 g/mol
•	: 2 g/mol : Not applicable for gases and gas mixtures.
- Molar mass	5

SECTION 10: Stability and reactivity	
10.1. Reactivity	
	No reactivity hazard other than the effects described in sub-sections below.
10.2. Chemical stability	
	Stable under normal conditions.
10.3. Possibility of hazardous reactions	
	None.
Reactivity	: This mixture contains components with the following reactivity : Can form explosive mixture with air. May react violently with oxidants.
10.4. Conditions to avoid	
	None under recommended storage and handling conditions (see section 7). Avoid moisture in installation systems.
10.5. Incompatible materials	
	For additional information on compatibility refer to ISO 11114.
10.6. Hazardous decomposition products	
	Under normal conditions of storage and use, hazardous decomposition products should not be produced.

SECTION 11: Toxicological information		
11.1. Information on hazard classes as defined in Regulation (EC) No 1272/2008		
Acute toxicity	: No toxicological effects from this product.	
Skin corrosion/irritation	: No known effects from this product.	
Serious eye damage/irritation	: No known effects from this product.	
Respiratory or skin sensitisation	: No known effects from this product.	
Germ cell mutagenicity	: No known effects from this product.	
Carcinogenicity	: No known effects from this product.	
Toxic for reproduction : Fertility	: No known effects from this product.	
Toxic for reproduction : unborn child	: No known effects from this product.	
STOT-single exposure	: No known effects from this product.	

STOT-repeated exposure : No known effects from this product.

	SAFETY DATA SHEET	Page : 8/11
Air Liquide		Revised edition no : 5.0
		Revision date : 2023-01-19
		Supersedes version of : 2021-06-1
	Hydrogen	NOAL_0067B
	, ,	Country : DK / Language : EN
Aspiration hazard	: Not applicable for gases and gas mixtures.	
11.2. Information on other hazards		
Other information	: The substance/mixture has no endocrine disrupting	g properties.
SECTION 12: Ecological infor	mation	
12.1. Toxicity		
Assessment	: No ecological damage caused by this product.	
EC50 48h - Daphnia magna [mg/l]	: No data available.	
EC50 72h - Algae [mg/l]	: No data available.	
LC50 96 h - Fish [mg/l]	: No data available.	
12.2. Persistence and degradability		
Assessment	: No ecological damage caused by this product.	
12.3. Bioaccumulative potential		
Assessment	: No data available.	
<u>12.4. Mobility in soil</u>		
Assessment	: Because of its high volatility, the product is unlikely Partition into soil is unlikely.	to cause ground or water pollution.
12.5. Results of PBT and vPvB asses	asment	
Assessment	: No data available.	
	Not classified as PBT or vPvB.	
12.6. Endocrine disrupting properties	<u>s</u>	
	The substance/mixture has no endocrine disrupting	g properties.
12.7. Other adverse effects		
Other adverse effects	: Can cause frost damage to vegetation.	
Effect on the ozone layer	: None.	
Effect on global warming	: No known effects from this product. None.	
SECTION 13: Disposal consid	derations	
13.1. Waste treatment methods		
	Contact supplier if guidance is required.	
	De net discharge inte areas where there is a risk of	f fammain an ann an a

List of hazardous waste codes (from Commission Decision 2000/532/EC as amended)	 Contact supplier if guidance is required. Do not discharge into areas where there is a risk of forming an explosive mixture with air. Waste gas should be flared through a suitable burner with flash back arrestor. Do not discharge into any place where its accumulation could be dangerous. Ensure that the emission levels from local regulations or operating permits are not exceeded. Refer to the EIGA code of practice Doc.30 "Disposal of Gases", downloadable at http://www.eiga.org for more guidance on suitable disposal methods. Return unused product in original container to supplier. 16 05 04 *: Gases in pressure containers (including halons) containing hazardous substances.
13.2. Additional information	
	External treatment and disposal of waste should comply with applicable local and/or national regulations.



: HYDROGEN, REFRIGERATED LIQUID

: HYDROGEN, REFRIGERATED LIQUID

: Hydrogen, refrigerated liquid

Page : 9/11 Revised edition no : 5.0

Revision date : 2023-01-19

Supersedes version of : 2021-06-17

Hydrogen

: 1966

NOAL_0067B Country : DK / Language : EN

SECTION 14: Transport information

14.1. UN number or ID number

In accordance with ADR / RID / IMDG / IATA / ADN UN-No.

14.2. UN proper shipping name

Transport by road/rail (ADR/RID) Transport by air (ICAO-TI / IATA-DGR) Transport by sea (IMDG)

14.3. Transport hazard class(es)



Transport by road/rail (ADR/RID)
Class
Classification code

Hazard identification number Tunnel Restriction

Transport by sea (IMDG)

Class / Div. (Sub. risk(s)) Emergency Schedule (EmS) - Fire Emergency Schedule (EmS) - Spillage

14.4. Packing group

Transport by road/rail (ADR/RID) Transport by air (ICAO-TI / IATA-DGR) Transport by sea (IMDG)

14.5. Environmental hazards

Transport by road/rail (ADR/RID) Transport by air (ICAO-TI / IATA-DGR) Transport by sea (IMDG)

14.6. Special precautions for user

Packing Instruction(s)

Transport by road/rail (ADR/RID) Transport by air (ICAO-TI / IATA-DGR) Passenger and Cargo Aircraft Cargo Aircraft only Transport by sea (IMDG)

Special transport precautions



2.1 : Flammable gases.

- : 2
- : 3F

: 223

- : B/D Tank carriage : Passage forbidden through tunnels of category B, C, D and E. Other carriage : Passage forbidden through tunnels of category D and E
- : 2.1 : F-D : S-U
- : Not established.
- Not established.Not established.
- : None.
- : None.
- : None.
- : P203
- : Forbidden.
- : Forbidden.
- : P203
- : Avoid transport on vehicles where the load space is not separated from the driver's compartment.

Ensure vehicle driver is aware of the potential hazards of the load and knows what to do in the event of an accident or an emergency.

- Before transporting product containers:
- Ensure there is adequate ventilation.
- Ensure that containers are firmly secured.
- Ensure valve is closed and not leaking.
- Ensure valve outlet cap nut or plug (where provided) is correctly fitted.
- Ensure valve protection device (where provided) is correctly fitted.



Page : 10/11

Revised edition no : 5.0 Revision date : 2023-01-19

Supersedes version of : 2021-06-17

Hydrogen

NOAL_0067B Country : DK / Language : EN

14.7. Maritime transport in bulk according to IMO instruments

No additional information available

SECTION 15: Regulatory information 15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture **EU-Regulations** Restrictions on use : None. National legislation : Ensure all national/local regulations are observed. Seveso Directive : 2012/18/EU (Seveso III) Listed. Covered. National regulations Ensure all national/local regulations are observed. Germany Water hazard class (WGK) : WGK nwg, Non-hazardous to water (Classification according to AwSV) National Rules and Recommendations [German regulations] BetriebssicherheitsV mit TRBSen insbesondere TRBS 3145 / TRGS 725 Ortsbewegliche Druckgasbehälter", TRBS 2141, BGRegel 500 Teil 2.33: "Umgang mit Gasen", GefahrstoffV mit Technischen Regeln Gefährliche Stoffe TRGS insbesondere TRGS 407 "Tätigkeiten mit Gasen - Gefährdungsbeurteilung", TRGS 400, 500, 510, 900." BGR 104, TRBS 2152. Netherlands SZW-lijst van kankerverwekkende stoffen : The substance is not listed SZW-lijst van mutagene stoffen The substance is not listed 2 SZW-lijst van reprotoxische stoffen - Borstvoeding The substance is not listed • SZW-lijst van reprotoxische stoffen -: The substance is not listed Vruchtbaarheid SZW-lijst van reprotoxische stoffen - Ontwikkeling : The substance is not listed Denmark **Danish National Regulations** : Young people below the age of 18 years are not allowed to use the product Switzerland Storage class (LK) : LK 2 - Liquefied or pressurized gases 15.2. Chemical safety assessment A CSA does not need to be carried out for this product.

SECTION 16: Other information

Indication of changes

: Safety data sheet in accordance with commission regulation (EU) No 2020/878.

	a :		:	:	4
U	н	r I	liq	u	de

Page : 11/11

Revised edition no : 5.0

Revision date : 2023-01-19 Supersedes version of : 2021-06-17

Hydrogen

NOAL_0067B
Country : DK / Language : EN

	Country : DK / Language : EN
Abbreviations and acronyms	: ATE - Acute Toxicity Estimate
	CLP - Classification Labelling Packaging Regulation; Regulation (EC) No 1272/2008
	REACH - Registration, Evaluation, Authorisation and Restriction of Chemicals Regulation
	(EC) No 1907/2006
	EINECS - European Inventory of Existing Commercial Chemical Substances
	CAS# - Chemical Abstract Service number
	PPE - Personal Protection Equipment
	LC50 - Lethal Concentration to 50 % of a test population
	RMM - Risk Management Measures
	PBT - Persistent, Bioaccumulative and Toxic
	vPvB - Very Persistent and Very Bioaccumulative
	STOT- SE : Specific Target Organ Toxicity - Single Exposure
	CSA - Chemical Safety Assessment
	EN - European Standard
	UN - United Nations
	ADR - European Agreement concerning the International Carriage of Dangerous Goods by
	Road
	IATA - International Air Transport Association
	IMDG code - International Maritime Dangerous Goods
	RID - Regulations concerning the International Carriage of Dangerous Goods by Rail
	WGK - Water Hazard Class
	STOT - RE : Specific Target Organ Toxicity - Repeated Exposure
	UFI : Unique Formula Identifier
Training advice	: Ensure operators understand the flammability hazard.
Further information	 Classification in accordance with the procedures and calculation methods of Regulation (EC) 1272/2008 (CLP).
	Key literature references and sources of data are maintained in EIGA doc 169 : 'Classification and Labelling Guide', downloadable at http://www.Eiga.eu
	Classification and Labelling Guide, downloadable at http://www.ciga.eu.

Full text of H- and EUH-statements		
Flam. Gas 1A	Flammable gases, Category 1A	
H220	Extremely flammable gas.	
H281	Contains refrigerated gas; may cause cryogenic burns or injury.	
Press. Gas (Ref. Liq.)	Gases under pressure : Refrigerated liquefied gas	
DISCLAIMER OF LIABILITY	: Before using this product in any new process or experiment, a thorough material	

compatibility and safety study should be carried out. Details given in this document are believed to be correct at the time of going to press. Whilst proper care has been taken in the preparation of this document, no liability for injury or damage resulting from its use can be accepted.

End of document