## SAFETY DATA SHEET

Page : 1/15 Revised edition no : 5.0

Revision date : 2024-02-02 Supersedes version of : 2023-01-21

## Silane

NOAL\_0107 Country : SE / Language : EN

SECTION 1: I	dentification of the substance/mixtu	ire and of the compar	ny/undertaking	
1.1. Product ider	tifier			
Trade name SDS no Other means of id	: Silane : NOAL_01 entification : Silane CAS-No. EC-No. EC Index	: 7803-62-5 : 232-263-4		
REACH registratio	on No : 01-21194			
Chemical formula	: SiH4			
1.2. Relevant ide	ntified uses of the substance or mixture and	uses advised against		
Relevant identified	Test gas/ Laborator Chemical Use for m	<ul> <li>Industrial and professional uses. Perform risk assessment prior to use.</li> <li>Test gas/Calibration gas.</li> <li>Laboratory use.</li> <li>Chemical reaction / Synthesis.</li> <li>Use for manufacture of electronic/photovoltaic components.</li> <li>Contact supplier for more information on uses.</li> </ul>		
Uses advised against : Consumer use. Uses other than those listed above are not supported, contact your supplier for m information on other uses.			oplier for more	
1.3. Details of the	e supplier of the safety data sheet			
Company identifi Supplier AIR LIQUIDE GA Pulpetgatan 20 215 37 Malmö - T +46 40 38 10 0 info.sweden@ain	AS AB SWEDEN 00			
E-Mail address (	competent person) : eunordic-sd	s@airliquide.com		
1.4. Emergency teleph	telephone number one number : 112 Availabili (24 / 7)	ty		
Country	Organisation/Company	Address	Emergency number	Comment
Germany	Giftnotruf Erfurt Gemeinsames Giftinformationszentrum der Länder Mecklenburg-Vorpommern, Sachsen, Sachsen-Anhalt und Thüringer	Nordhäuser Straße 74 99089 Erfurt	+49 (0) 361 730 730	

### **SECTION 2: Hazards identification**

#### 2.1. Classification of the substance or mixture

#### Classification according to Regulation (EC) No. 1272/2008 [CLP]

c/o HELIOS Klinikum Erfurt

Physical hazards Flammable gases, Category 1A

	SAFETY DA	TA SHEFT Page : 2/15		
🖸 Air Liquid		Revised edition no : 5.0		
		Revision date : 2024-02-02		
		Supersedes version of : 2023-01-21		
	Silane	NOAL_0107		
		Country : SE / Language : EN		
(	Bases under pressure : Liquefied gas	H280		
Health hazards A	cute toxicity (inhalation:gas) Category 4	H332		
2.2. Label elements				
Labelling according to Reg	ulation (EC) No. 1272/2008 [CLP]			
Hazard pictograms (CLP)				
Signal word (CLP)	GHS02 G : Danger	GHS04 GHS07		
Hazard statements (CLP)	: H220 - Extremely fla	ammable das		
	H280 - Contains gas	H280 - Contains gas under pressure; may explode if heated. H332 - Harmful if inhaled.		
Precautionary statements (C				
- Prevention	P271 - Use only out P210 - Keep away fr No smoking.	ing dust/fume/gas/mist/vapours/spray. doors or in a well-ventilated area. rom heat, hot surfaces, sparks, open flames and other ignition sources. rom heat, hot surfaces, sparks, open flames and other ignition sources.		
- Response	: P304+P340 - IF INH P377 - Leaking gas P381 - In case of lea P381 - In case of lea	IALED: Remove person to fresh air and keep comfortable for breathing. fire: Do not extinguish, unless leak can be stopped safely. akage, eliminate all ignition sources. akage, eliminate all ignition sources. DN CENTRE or doctor if you feel unwell.		
- Storage	: P403 - Store in a we	<ul> <li>P403 - Store in a well-ventilated place.</li> <li>P410+P403 - Protect from sunlight. Store in a well-ventilated place.</li> </ul>		
2.3. Other hazards				
	Contact with liquid m May ignite spontane Not classified as PB	eously if exposed to air. nay cause cold burns/frostbite. eously in contact with air. BT or vPvB. ure has no endocrine disrupting properties.		

### **SECTION 3: Composition/information on ingredients**

### 3.1. Substances

Name	Product identifier	Composition [V- %]:	Classification according to Regulation (EC) No. 1272/2008 [CLP]
Silane	CAS-No.: 7803-62-5 EC-No.: 232-263-4 EC Index-No.: REACH registration No: 01-2119436667- 29	100	Flam. Gas 1A, H220 Press. Gas (Liq.), H280

Contains no other components or impurities which will influence the classification of the product.

# SAFETY DATA SHEET

Page : 3/15

Revised edition no : 5.0

Revision date : 2024-02-02 Supersedes version of : 2023-01-21

## Silane

NOAL\_0107 Country : SE / Language : EN

3.2. Mixtures

Not established.

4.1. Description of first aid measures			
- Inhalation	: Remove victim to uncontaminated area wearing self contained breathing apparatus. Keep victim warm and rested. Call a doctor. Perform cardiopulmonary resuscitation if breathing stopped.		
- Skin contact	: In case of frostbite spray with water for at least 15 minutes. Apply a sterile dressing. Obtain medical assistance.		
- Eye contact	: Immediately flush eyes thoroughly with water for at least 15 minutes.		
- Ingestion	: Ingestion is not considered a potential route of exposure.		
4.2. Most important symptoms and effects, bo	oth acute and delayed		
	May cause headache, nausea and irritation of respiratory tract. See section 11.		
4.3. Indication of any immediate medical atter	ntion and special treatment needed		
	Obtain medical assistance.		
SECTION 5: Firefighting measures			
5.1. Extinguishing media			
- Suitable extinguishing media	: Water spray or fog. Dry powder.		
	Shutting off the source of the gas is the preferred method of control.		
<ul> <li>Unsuitable extinguishing media</li> </ul>	: Carbon dioxide.		
	Do not use water jet to extinguish.		
5.2. Special hazards arising from the substan	ice or mixture		
Specific hazards	: Exposure to fire may cause containers to rupture/explode.		
	Escaping gas cannot be extinguished.		
Hazardous combustion products	: Silica dust (inert - but may irritate respiratory tract and eyes).		
5.3. Advice for firefighters			
Specific methods	<ul> <li>Use fire control measures appropriate for the surrounding fire. Exposure to fire and heat radiation may cause gas receptacles to rupture. Cool endangered receptacles with water spray jet from a protected position. Prevent water used in emergency cases from entering sewers and drainage systems.</li> <li>If possible, stop flow of product.</li> <li>Use water spray or fog to knock down fire fumes if possible.</li> <li>Do not extinguish a leaking gas flame unless absolutely necessary. Spontaneous/explosive re-ignition may occur. Extinguish any other fire.</li> <li>Move containers away from the fire area if this can be done without risk.</li> </ul>		
Special protective equipment for fire fighters	<ul> <li>Wear gas tight chemically protective clothing in combination with self contained breathing apparatus.</li> <li>Standard EN 943-2: Protective clothing against liquid and gaseous chemicals, aerosols an solid particles. Gas-tight chemical protective suits for emergency teams.</li> <li>Standard EN 137 - Self-contained open-circuit compressed air breathing apparatus with fu face mask.</li> </ul>		

## SAFETY DATA SHEET

Page : 4/15

Revised edition no : 5.0 Revision date : 2024-02-02

Supersedes version of : 2023-01-21

### Silane

NOAL\_0107 Country : SE / Language : EN

#### **SECTION 6: Accidental release measures**

6.1. Personal precautions, protective equipment and emergency procedures			
For non-emergency personnel	<ul> <li>Act in accordance with local emergency plan.</li> <li>Try to stop release.</li> <li>Evacuate area.</li> <li>Ensure adequate air ventilation.</li> <li>Stay upwind.</li> <li>See section 8 of the SDS for more information on personal protective equipment</li> </ul>		
For emergency responders	: Wear self-contained breathing apparatus when entering area unless atmosphere is proved to be safe. See section 5.3 of the SDS for more information.		
6.2. Environmental precautions			
	Try to stop release.		
6.3. Methods and material for containment and cle	eaning up		
	Ventilate area. Keep area evacuated and free from ignition sources until any spilled liquid has evaporated (ground free from frost). Dust deposited may be vacuum cleaned or the area hosed down with water.		
6.4. Reference to other sections	See also sections 8 and 13.		

### **SECTION 7: Handling and storage**

### 7.1. Precautions for safe handling

Safe use of the product : Gas cabinets, rooms or indoor areas where product is stored or used shall be protected by an automatic sprinkler system. Do not breathe gas. Avoid release of product into atmosphere. For more guidance on safe use, refer to the EIGA Doc.160 "Storage and handling of silane and silane mixtures", downloadable at http://www.eiga.eu and consult your supplier. The product must be handled in accordance with good industrial hygiene and safety procedures. Only experienced and properly instructed persons should handle gases under pressure. Consider pressure relief device(s) in gas installations. Ensure the complete gas system was (or is regularily) checked for leaks before use. Do not smoke while handling product. Avoid exposure, obtain special instructions before use. Use only properly specified equipment which is suitable for this product, its supply pressure and temperature. Contact your gas supplier if in doubt. Avoid suck back of water, acid and alkalis. Assess the risk of potentially explosive atmospheres and the need for explosion-proof equipment. Purge air from system before introducing gas. Take precautionary measures against static discharge. Keep away from ignition sources (including static discharges). Consider the use of only non-sparking tools. A manually activated deluge water spray fire protection system shall be provided to protect bulk product delivery systems. Ensure equipment is adequately earthed.

Period         Revised edition no: 5.0           Revision date: 2024-024         Supersedes version of: 2023           Supersedes version of: 2023         NOAL_0107           Country: SE / Language:         Country: SE / Language:           Bafe handling of the gas receptade         : Refer to supplier's container handling instructions. Do not allow backfeed into the container. Protect containers from physical damage; do not drag, roll, slide or drop. When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders. Leave valve protection caps in place until the container has been secured against eithe wall to bench or placed in a container stand and is ready for use. If user experiences any diffculty operating valve discontinue use and contact supplier. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immodately to the supplier. Keep container valve outlets clean and free from contaminants particularly oil and wale Replace valve outlet caps or plugs and container caps where supplied as soon as conta is disconnected from equipment. Close container valve after each use and when empty, even if still connected to equipm Never attempt to transfer gases from one cylinder/container to another. Never use direct flame or electrical heating devices to raise the pressure of a container. Do not remove or deface labels provided by the supplier for the identification of the con of the container. Suck back of water into the container must be prevented. Open valve slowly to avoid pressure shock.           7.2. Conditions for safe storage, including any incompatibilities         Observe all regulations and local requirements regarding storage of containers. Containers should be stored in the vertical position		SAFETY DATA SHEET	Page : 5/15	
Silane         NOAL_0107           Supersedes version of : 2023           Safe handling of the gas receptade         : Refer to supplier's container handling instructions. Do not allow backdeed into the container. Protect containers from physical damage: do not drag, roll, slide or drop. When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders. Leave valve protection caps in place until the container has been secured against eithe wall or bench or placed in a container stand and is ready for use. If user experiences any diffculty operating valve discontinue use and contact supplier. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier data soon as conta is disconnected from equipment. Close container valve outlets clean and free from contaminants particularly oil and wate Replace valve outlet caps or plugs and container caps where supplied as soon as conta is disconnected from equipment. Close container valve after each use and when empty, even if still connected to equipm Never attempt to transfer gases from one cylinder/container to another. Never use direct flame or electrical heating devices to raise the pressure of a container. Do not remove or deface labels provided by the supplier for the identification of the cont of the container. Suck back of water into the container must begrading storage of containers. Containers should not be stored in conditions likely to encorage corrosion. Containers valve galverds or caps should be in place. Containers should be stored in the vertical position and properly secured to preven the from falling over. Store containers hould be stored in the vertical position and leakage. Keep containere belo		OAIEIT DATA ONEET	Revised edition no : 5.0	
Silane         NOAL_0107           Country : SE / Language :         Safe handling of the gas receptacle         : Refer to supplier's container handling instructions. Do not allow backfeed into the container. Protect containers from physical damage; do not drag, roll, slide or drop. When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders. Leave valve protection caps in place until the container has been secured against eithe wall or bench or placed in a container stand and is ready for use. If user experiences any difficulty operating valve discontinue use and contact supplier. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier. Keep container valve outlets clean and free from contaminants particularly oil and wate Replace valve outlet caps or plugs and container caps where supplied as soon as conta is disconnected from equipment. Close container valve dafer each use and when empty, even if still connected to equipm Never attempt to transfer gases from one cylinder/container to another. Never use direct flame or electrical heating devices to raise the pressure of a container. Do not remove or deface labels provided by the supplier for the identification of the cont of the container. Suck back of water into the container must be prevented. Open valve slowly to avoid pressure shock.           7.2. Conditions for safe storage, including any incompatibilities         Observe all regulations and local requirements regarding storage of containers. Containers should be stored in the vertical position and properly secured to prevent the from falling over. Stored containers should be periodically checked for general condition and leakage. Keep containers in location free from fire risk and away from sources of heat and ignitic Keep away from combustible materia	<b>G</b> HII LIQUIDE		Revision date : 2024-02-02	
Country : SE / Language :           Safe handling of the gas receptacle         : Refer to supplier's container handling instructions. Do not allow backfeed into the container. Protect containers from physical damage; do not drag, roll, slide or drop. When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders. Leave valve protection caps in place until the container has been secured against eithe wall or bench or placed in a container stand and is ready for use. If user experiences any difficulty operating valve discontinue use and contact supplier. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier. Keep container valve outlet caps or plugs and container caps where supplied as soon as conta is disconnected from equipment. Close container valve after each use and when empty, even if still connected to equipm Never attempt to transfer gases from one cylinder/container to another. Never use direct flame or electrical heating devices to raise the pressure of a container. Never use direct flame or electrical heating devices to raise the pressure of a container. Do not remove or deface labels provided by the supplier for the identification of the cont of the container. Suck back of water into the container must be prevented. Open valve slowly to avoid pressure shock.           7.2. Conditions for safe storage, including any incompatibilities         Observe all regulations and local requirements regarding storage of containers. Containers should not be stored in condition slikely to encourage corrosion. Container valve guards or caps should be in place. Containers should be periodically checked for general condition and leakage. Keep container in location free from fire firs, and away from sources of heat and ignitic Keep away from combustible materials. Segregate from oxidant g			Supersedes version of : 2023-01-2	
Safe handling of the gas receptacle       : Refer to supplier's container handling instructions.         Do not allow backled into the container.       Protect containers from physical damage; do not drag, roll, slide or drop.         When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders.       Leave valve protection caps in place until the container has been secured against eithe wall or bench or placed in a container stand and is ready for use.         If user experiences any difficulty operating valve discontinue use and contact supplier.       Never attempt to repair or modify container valves or safety relief devices.         Damaged valves should be reported immediately to the supplier.       Keep container valve outlet caps or plugs and container as were supplied as soon as conta is disconnected from equipment.         Close container valve after each use and when empty, even if still connected to equipm Never attempt to transfer gases from one cylinder/container to another.         Never use direct flame or electrical heating devices to raise the pressure of a container.         Do not remove or deface labels provided by the supplier for the identification of the container.         Suck back of water into the container must be prevented.         Open valve slowly to avoid pressure shock.         7.2. Conditions for safe storage, including any incompatibilities         Observe all regulations and local requirements regarding storage of containers.         Containers should not be stored in conditions likely to encourage corrosion.		Silane	NOAL_0107	
Do not allow backfeed into the container. Protect containers from physical damage; do not drag, roll, slide or drop. When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders. Leave valve protection caps in place until the container has been secured against eithe wall or bench or placed in a container stand and is ready for use. If user experiences any difficulty operating valve discontinue use and contact supplier. Never attempt to repair or modify container valves or safety relief devices. Damaged valves should be reported immediately to the supplier. Keep container valve outlets clean and free from contaminants particularly oil and wate Replace valve outlet caps or plugs and container caps where supplied as soon as conta is disconnected from equipment. Close container valve after each use and when empty, even if still connected to equipm Never attempt to transfer gases from one cylinder/container to another. Never use direct flame or electrical heating devices to raise the pressure of a container. Do not remove or deface labels provided by the supplier for the identification of the cont of the container. Suck back of water into the container must be prevented. Open valve slowly to avoid pressure shock. <b>7.2. Conditions for safe storage, including any incompatibilities</b> Observe all regulations and local requirements regarding storage of containers. Containers should not be stored in conditions likely to encourage corrosion. Container valve guards or caps should be in place. Containerer should be retored in the vertical position and properly secured to prevent the from falling over. Stored containers holds the stored in the vertical position and properly secured to prevent the from falling over. Stored containers in location free from fire risk and away from sources of heat and ignitid Keep away from condusting tages and other oxidants in store. All electrical equipment in the storage areas should be compatible with the			Country : SE / Language : EN	
Containers should not be stored in conditions likely to encourage corrosion. Container valve guards or caps should be in place. Containers should be stored in the vertical position and properly secured to prevent the from falling over. Stored containers should be periodically checked for general condition and leakage. Keep container below 50°C in a well ventilated place. Store containers in location free from fire risk and away from sources of heat and ignitic Keep away from combustible materials. Segregate from oxidant gases and other oxidants in store. All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.	Safe handling of the gas receptacle	Do not allow backfeed into the container. Protect containers from physical damage; do not dra When moving cylinders, even for short distances, us designed to transport cylinders. Leave valve protection caps in place until the contain wall or bench or placed in a container stand and is re If user experiences any difficulty operating valve disc Never attempt to repair or modify container valves of Damaged valves should be reported immediately to Keep container valve outlets clean and free from cor Replace valve outlet caps or plugs and container cap is disconnected from equipment. Close container valve after each use and when emp Never attempt to transfer gases from one cylinder/co Never use direct flame or electrical heating devices t Do not remove or deface labels provided by the supp of the container. Suck back of water into the container must be preve	<ul> <li>Refer to supplier's container handling instructions.</li> <li>Do not allow backfeed into the container.</li> <li>Protect containers from physical damage; do not drag, roll, slide or drop.</li> <li>When moving cylinders, even for short distances, use a cart (trolley, hand truck, etc.) designed to transport cylinders.</li> <li>Leave valve protection caps in place until the container has been secured against either a wall or bench or placed in a container stand and is ready for use.</li> <li>If user experiences any difficulty operating valve discontinue use and contact supplier.</li> <li>Never attempt to repair or modify container valves or safety relief devices.</li> <li>Damaged valves should be reported immediately to the supplier.</li> <li>Keep container valve outlets clean and free from contaminants particularly oil and water.</li> <li>Replace valve outlet caps or plugs and container caps where supplied as soon as container is disconnected from equipment.</li> <li>Close container valve after each use and when empty, even if still connected to equipment Never attempt to transfer gases from one cylinder/container to another.</li> <li>Never use direct flame or electrical heating devices to raise the pressure of a container.</li> <li>Do not remove or deface labels provided by the supplier for the identification of the content of the container.</li> </ul>	
Containers should not be stored in conditions likely to encourage corrosion. Container valve guards or caps should be in place. Containers should be stored in the vertical position and properly secured to prevent the from falling over. Stored containers should be periodically checked for general condition and leakage. Keep container below 50°C in a well ventilated place. Store containers in location free from fire risk and away from sources of heat and ignitic Keep away from combustible materials. Segregate from oxidant gases and other oxidants in store. All electrical equipment in the storage areas should be compatible with the risk of a potentially explosive atmosphere.	7.2. Conditions for safe storage, includ		line to see the installed	
		Containers should not be stored in conditions likely t Container valve guards or caps should be in place. Containers should be stored in the vertical position a from falling over. Stored containers should be periodically checked for Keep container below 50°C in a well ventilated place Store containers in location free from fire risk and aw Keep away from combustible materials. Segregate from oxidant gases and other oxidants in All electrical equipment in the storage areas should b	o encourage corrosion. and properly secured to prevent them general condition and leakage. a. vay from sources of heat and ignition. store.	
<u><i>I.3.</i> Specific end use(s)</u>	7.3. Specific end use(s)			

## SECTION 8: Exposure controls/personal protection

### 8.1. Control parameters

Silane (7803-62-5)			
Belgium - Occupational Exposure Limits			
Local name	Silicium (tétrahydrure de) # Siliciumtetrahydride		
OEL TWA	6.7 mg/m <sup>3</sup>		
EL TWA [ppm] 5 ppm			
Denmark - Occupational Exposure Limits			
Local name	Silan (Siliciumtetrahydrid)		
OEL TWA [1]	WA [1] 0.7 mg/m <sup>3</sup>		
OEL TWA [2]	0.5 ppm		

# SAFETY DATA SHEET

Page : 6/15

Revised edition no : 5.0

Revision date : 2024-02-02 Supersedes version of : 2023-01-21

## Silane

NOAL_0107	
Country : SE / Language :	ΕN

#### Estonia - Occupational Exposure Limits

Estoria - Occupational Exposure Elimits	
Local name	Silaan
OEL TWA	1 mg/m³
OEL TWA [ppm]	0.5 ppm
Finland - Occupational Exposure Limits	
Local name	Piitetrahydridi
HTP (OEL TWA) [1]	0.67 mg/m³
HTP (OEL TWA) [2]	0.5 ppm
HTP (OEL STEL)	2 mg/m <sup>3</sup>
HTP (OEL STEL) [ppm]	1.5 ppm
France - Occupational Exposure Limits	
Local name	Tétrahydrure de silicium
VME (OEL TWA)	7 mg/m <sup>3</sup>
VME (OEL TWA) [ppm]	5 ppm
Remark	Valeurs recommandées/admises
Greece - Occupational Exposure Limits	
OEL TWA	7 mg/m³
OEL TWA [ppm]	5 ppm
Ireland - Occupational Exposure Limits	
Local name	Silane
OEL TWA [1]	0.7 mg/m³
OEL TWA [2]	0.5 ppm
OEL STEL	1.5 mg/m <sup>3</sup>
OEL STEL [ppm]	1 ppm
Spain - Occupational Exposure Limits	
Local name	Silano (Tetrahidruro de silicio)
VLA-ED (OEL TWA) [1]	6.7 mg/m³
VLA-ED (OEL TWA) [2]	5 ppm
United Kingdom - Occupational Exposure Limits	
Local name	Silane
WEL TWA (OEL TWA) [1]	0.67 mg/m³
WEL TWA (OEL TWA) [2]	0.5 ppm
WEL STEL (OEL STEL)	1.3 mg/m³
WEL STEL (OEL STEL) [ppm]	1 ppm

OEL TWA [ppm]

# **SAFETY DATA SHEET**

Page : 7/15

Revised edition no : 5.0

Revision date : 2024-02-02 Supersedes version of : 2023-01-21

### Cilano

Silane		NOAL_0107
		Country : SE / Language : EN
Iceland - Occupational Exposure Limits		
Local name	Sílan (kísill)	
OEL TWA	0.7 mg/m³	
OEL TWA [ppm]	0.5 ppm	
Norway - Occupational Exposure Limits		
Local name	Silan	
Grenseverdi (OEL TWA) [1]	0.7 mg/m³	
Grenseverdi (OEL TWA) [2]	0.5 ppm	
Switzerland - Occupational Exposure Limits		
Local name	Silan (s. Siliciumtetrahydrid)	
MAK (OEL TWA) [1]	0.7 mg/m³ 0.7 mg/m³	
MAK (OEL TWA) [2]	0.5 ppm 0.5 ppm	
Remark	OAW & Haut	
USA - ACGIH - Occupational Exposure Limits		
Local name	Silicon tetrahydride	
ACGIH OEL TWA [ppm]	5 ppm	
Remark (ACGIH)	URT & skin irr	
Silane (7803-62-5)		
Belgium - Occupational Exposure Limits		
Local name	Silicium (tétrahydrure de) # Siliciumte	etrahydride
OEL TWA	6.7 mg/m³	

Denmark - Occupational Exposure Limits

Denmark - Occupational Exposure Limits		
Local name	Silan (Siliciumtetrahydrid)	
OEL TWA [1]	0.7 mg/m³	
OEL TWA [2]	0.5 ppm	
Estonia - Occupational Exposure Limits		
Local name	Silaan	
OEL TWA	1 mg/m³	
OEL TWA [ppm]	0.5 ppm	
Finland - Occupational Exposure Limits		
Local name	Piitetrahydridi	
HTP (OEL TWA) [1]	0.67 mg/m <sup>3</sup>	

5 ppm

	Ai	rl	Lia	ui	de
$\mathbf{\nabla}$					<b>u</b> u

# SAFETY DATA SHEET

Page : 8/15

Revised edition no : 5.0

Revision date : 2024-02-02 Supersedes version of : 2023-01-21

NOAL\_0107

## Silane

HTP (OEL TWA) [2] 0.5 ppm	Country : SE / Language : EN	
HTP (OEL STEL) 2 mg/m <sup>3</sup>		
HTP (OEL STEL) [ppm] 1.5 ppm		
France - Occupational Exposure Limits		
Local name Tétrahydrure de silicium		
VME (OEL TWA) 7 mg/m <sup>3</sup>		
VME (OEL TWA) [ppm] 5 ppm		
Remark Valeurs recommandées/admises		
Greece - Occupational Exposure Limits		
OEL TWA 7 mg/m <sup>3</sup>		
OEL TWA [ppm] 5 ppm		
Ireland - Occupational Exposure Limits		
Local name Silane		
OEL TWA [1] 0.7 mg/m <sup>3</sup>		
OEL TWA [2] 0.5 ppm		
OEL STEL 1.5 mg/m <sup>3</sup>		
OEL STEL [ppm] 1 ppm		
Spain - Occupational Exposure Limits		
Local name Silano (Tetrahidruro de silicio)		
VLA-ED (OEL TWA) [1] 6.7 mg/m <sup>3</sup>		
VLA-ED (OEL TWA) [2] 5 ppm		
United Kingdom - Occupational Exposure Limits		
Local name Silane		
WEL TWA (OEL TWA) [1] 0.67 mg/m <sup>3</sup>		
WEL TWA (OEL TWA) [2] 0.5 ppm		
WEL STEL (OEL STEL) 1.3 mg/m <sup>3</sup>		
WEL STEL (OEL STEL) [ppm] 1 ppm		
Iceland - Occupational Exposure Limits		
Local name Sílan (kísill)		
OEL TWA 0.7 mg/m <sup>3</sup>		
OEL TWA [ppm] 0.5 ppm		
Norway - Occupational Exposure Limits		
Local name Silan		
Grenseverdi (OEL TWA) [1] 0.7 mg/m <sup>3</sup>		

## SAFETY DATA SHEET

Page : 9/15

Revised edition no : 5.0

Revision date : 2024-02-02 Supersedes version of : 2023-01-21

## Silane

NOAL\_0107 Country : SE / Language : EN

#### Switzerland - Occupational Exposure Limits

Local name	Silan (s. Siliciumtetrahydrid)	
MAK (OEL TWA) [1]	0.7 mg/m <sup>3</sup> 0.7 mg/m <sup>3</sup>	
MAK (OEL TWA) [2]	0.5 ppm 0.5 ppm	
Remark	OAW & Haut	
USA - ACGIH - Occupational Exposure Limits		
Local name	Silicon tetrahydride	
ACGIH OEL TWA [ppm]	5 ppm	
Remark (ACGIH)	URT & skin irr	

Silane (7803-62-5)	
DNEL: Derived no effect level (Workers)	
Acute - systemic effects, inhalation	0.67 mg/m <sup>3</sup>
Long-term - systemic effects, inhalation	0.67 mg/m³

Silane (7803-62-5)		
DNEL: Derived no effect level (Workers)		
Acute - systemic effects, inhalation		0.67 mg/m <sup>3</sup>
Long-term - systemic effects, inhalation		0.67 mg/m <sup>3</sup>
PNEC (Predicted No-Effect Concentration)	: None establi	shed.
8.2. Exposure controls		
8.2.1. Appropriate engineering controls		
	Provide adec	uate general and local exhaust ventilation.
	Product to be	handled in a closed system

	Flouder to be handled in a closed system.
	Systems under pressure should be regularily checked for leakages.
	Ensure exposure is below occupational exposure limits (where available).
	Gas detectors should be used when toxic gases may be released.
	Consider the use of a work permit system e.g. for maintenance activities.
	Optical flame detection systems shall be provided to detect a fire at potential leak points.
8.2.2. Individual protection measures, e	e.g. personal protective equipment
	A risk assessment should be conducted and documented in each work area to assess the
	risks related to the use of the product and to select the PPE that matches the relevant risk.
	The following recommendations should be considered:
	PPE compliant to the recommended EN/ISO standards should be selected.
<ul> <li>Eye/face protection</li> </ul>	: Wear goggles and a face shield when transfilling or breaking transfer connections.
	Standard EN 166 - Personal eye-protection - specifications.
Skin protection	
- Hand protection	: Wear working gloves when handling gas containers.
	Standard EN 388 - Protective gloves against mechanical risk, performance level 1 or higher.
	Standard EN 511 - Cold insulating gloves.

## **SAFETY DATA SHEET**

Page : 10/15

Revised edition no : 5.0

Revision date : 2024-02-02 Supersedes version of : 2023-01-21

	Silane	NOAL_0107
		Country : SE / Language : EN
- Other	: Consider the use of flame resistant anti-static safety clo	othing.
	Standard EN ISO 14116 - Limited flame spread materia	als.
	Standard EN 1149-5 - Protective clothing: Electrostatic	properties.
	Depending on operations that e.g. involve opening of va	alves or opening of process silane
	systems the following additional PPE shall be considered	ed: Hard hat, fire resistant hood, face
	shield, leather gauntlet.	
	Wear safety shoes while handling containers.	
	Standard EN ISO 20345 - Personal protective equipme	-
<ul> <li>Respiratory protection</li> </ul>	: Gas filters may be used if all surrounding conditions e.g	g. type and concentration of the
	contaminant(s) and duration of use are known.	
	Standard EN 137 - Self-contained open-circuit compres	ssed air breathing apparatus with full
	face mask.	
	Consult respiratory device supplier's product informatio	on for the selection of the appropriate
	device.	
	Gas filters do not protect against oxygen deficiency.	d standard EN420, full face masks
	Standard EN 14387 - Gas filter(s), combined filter(s) an	
	Keep self contained breathing apparatus readily availab	0,
	Self contained breathing apparatus is recommended, w	
• Thermal hazards	expected, e.g. during maintenance activities on installat None in addition to the above sections.	lion systems.
8.2.3. Environmental exposure controls		
	Refer to local regulations for restriction of emissions to specific methods for waste gas treatment.	the atmosphere. See section 13 for

## **SECTION 9: Physical and chemical properties**

9.1. Information on basic physical and chemical properties
--

9.1. Information on basic physical and chemic	al properties
Appearance	
- Physical state at 20°C / 101.3kPa	: Gas
- Colour	: Colourless.
Odour	: No odour warning properties.
	Odour threshold is subjective and inadequate to warn of overexposure.
рН	: Not applicable for gases and gas mixtures.
Melting point / Freezing point	: -186 °C
	-186 °C
Boiling point	: -111 °C
Flash point	: Not applicable for gases and gas mixtures.
Flammability	: Extremely flammable gas
Explosive limits	: Pyrophoric.
Lower explosion limit	: Not available
Upper explosion limit	: Not available
Vapour pressure [20°C]	: Not applicable.
Vapour pressure [50°C]	: Not applicable.
Density	: Not applicable
Vapour density	: Not applicable for gases and gas mixtures.
Relative density, liquid (water=1)	: 0.55
Relative density, gas (air=1)	: 1.1
Water solubility	: No reliable data available.
Partition coefficient n-octanol/water (Log Kow)	: Not applicable for inorganic products.
Auto-ignition temperature	: -50 °C
Decomposition temperature	: Not applicable.
Viscosity, kinematic	: No reliable data available.
Particle characteristics	: Not applicable for gases and gas mixtures.

	Air	lia	uid	ما
U	пп	LIQ	uiu	e

# **SAFETY DATA SHEET**

Page : 11/15 Revised edition no : 5.0

Revision date : 2024-02-02

Supersedes version of : 2023-01-21

## Silane

**NOAL 0107** Country : SE / Language : EN

#### 9.2. Other information

9.2.1. Information with regard to physical hazard	classes
Explosive properties Oxidising properties Tci Critical temperature [°C]	<ul> <li>Not applicable.</li> <li>Not applicable.</li> <li>1 %</li> <li>-3.5 °C</li> </ul>
9.2.2. Other safety characteristics	
Molar mass Evaporation rate Gas group	<ul> <li>32 g/mol</li> <li>Not applicable for gases and gas mixtures.</li> <li>Press. Gas (Liq.)</li> </ul>

SECTION 10: Stability and reactivity	
10.1. Reactivity	
	No reactivity hazard other than the effects described in sub-sections below.
10.2. Chemical stability	
	Stable under normal conditions.
10.3. Possibility of hazardous reactions	
Reactivity	None. : This mixture contains components with the following reactivity : Can form explosive mixture with air. May react violently with oxidants. Can ignite spontaneously in air (fire cannot be put out). Can form spontaneous, violently explosive mixture in air.
10.4. Conditions to avoid	
	None under recommended storage and handling conditions (see section 7). Avoid moisture in installation systems.
10.5. Incompatible materials	
	For additional information on compatibility refer to ISO 11114.
10.6. Hazardous decomposition products	
	Under normal conditions of storage and use, hazardous decomposition products should not be produced.

SECTION 11: Toxicological information		
11.1. Information on hazard classes as defined in Regulation (EC) No 1272/2008		
Acute toxicity	Harmful if inhaled.	
LC50 Inhalation - Rat [ppm]	9500 ppm/4h	
Silane (7803-62-5)		

LC50 Inhalation - Rat [ppm]	9500 ppm/4h
Skin corrosion/irritation	No known effects from this product.
Serious eye damage/irritation	No known effects from this product.
Respiratory or skin sensitisation	No known effects from this product.
Germ cell mutagenicity	No known effects from this product.
Carcinogenicity	No known effects from this product.
Toxic for reproduction : Fertility	No known effects from this product.
Toxic for reproduction : unborn child	No known effects from this product.

	SAFETY DATA SHEET	Page : 12/15
<b>O</b> Air Liquide		Revised edition no : 5.0
		Revision date : 2024-02-02
		Supersedes version of : 2023-01-21
	Silane	
		Country : SE / Language : EN
STOT-single exposure	: May cause nausea and irritation of the respiratory tract. Hydrolysis of silanes in the body forms silicic acid or hydrated silica.	
STOT-repeated exposure	: No known effects from this product.	
Aspiration hazard	: Not applicable for gases and gas mixtures.	
11.2. Information on other hazards		
Other information	: The substance/mixture has no endocrine disrupting p	properties.

### **SECTION 12: Ecological information**

#### 12.1. Toxicity

Assessment	: No data available.
EC50 48h - Daphnia magna [mg/l]	: No data available.
EC50 72h - Algae [mg/l]	: No data available.
LC50 96 h - Fish [mg/l]	: No data available.
12.2. Persistence and degradability	
Assessment	: Not applicable for inorganic products.
12.3. Bioaccumulative potential	
Assessment	: No data available.
<u>12.4. Mobility in soil</u>	
Assessment	: Because of its high volatility, the product is unlikely to cause ground or water pollution. Partition into soil is unlikely.
12.5. Results of PBT and vPvB assessment	
Assessment	: Not classified as PBT or vPvB.
12.6. Endocrine disrupting properties	
	The substance/mixture has no endocrine disrupting properties.
12.7. Other adverse effects	
Other adverse effects	: No known effects from this product.
Effect on the ozone layer	: None.
Effect on global warming	: No known effects from this product.

#### **SECTION 13: Disposal considerations**

#### 13.1. Waste treatment methods Contact supplier if guidance is required. Do not discharge into areas where there is a risk of forming an explosive mixture with air. Waste gas should be flared through a suitable burner with flash back arrestor. Must not be discharged to atmosphere. Gases formed by combustion should be washed with water to remove silica. Ensure that the emission levels from local regulations or operating permits are not exceeded. Refer to the EIGA code of practice Doc.30 "Disposal of Gases", downloadable at http://www.eiga.org for more guidance on suitable disposal methods. Return unused product in original container to supplier. List of hazardous waste codes (from Commission 16 05 04 \*: Gases in pressure containers (including halons) containing hazardous Decision 2000/532/EC as amended) substances. 13.2. Additional information External treatment and disposal of waste should comply with applicable local and/or national regulations.

	SAFETY DATA SHEET	Page : 13/15 Revised edition no : 5.0
Air Liquide		Revised edition no : 5.0 Revision date : 2024-02-02
		Supersedes version of : 2023-01-21
	Silane	NOAL_0107
	Shahe	Country : SE / Language : EN
SECTION 14: Transport info	rmation	
14.1. UN number or ID number		
In accordance with ADR / RID / IMDG UN-No.	; / IATA / ADN : 2203	
14.2. UN proper shipping name		
Transport by road/rail (ADR/RID)	: SILANE	
Transport by air (ICAO-TI / IATA-DG	GR) : Silane	
Transport by sea (IMDG)	: SILANE	
14.3. Transport hazard class(es)	•	
Labelling		
Transport by road/roll (ADB/BID)	2.1 : Flammable gases.	
Transport by road/rail (ADR/RID) Class	: 2	
Classification code	: 2F	
Hazard identification number	: 23	
Tunnel Restriction	: B/D - Tank carriage: Passage forbidden through t carriage: Passage forbidden through tunnels of c	
Transport by sea (IMDG)		
Class / Div. (Sub. risk(s)) Emergency Schedule (EmS) - Fire	: 2.1 : F-D	
Emergency Schedule (EmS) - Spillage		
14.4. Packing group		
Transport by road/rail (ADR/RID)	: Not established.	
Transport by air (ICAO-TI / IATA-DGF		
Transport by sea (IMDG)	: Not established.	
14.5. Environmental hazards		
Transport by road/rail (ADR/RID)	: None.	
Transport by air (ICAO-TI / IATA-DGF Transport by sea (IMDG)	R) : None. : None.	
14.6. Special precautions for user		
Packing Instruction(s) Transport by road/rail (ADR/RID)	: P200	
Transport by air (ICAO-TI / IATA-DGF		
Passenger and Cargo Aircraft	: Forbidden.	
Cargo Aircraft only	: Forbidden.	
Transport by sea (IMDG)	: P200	
Special transport precautions	<ul> <li>Avoid transport on vehicles where the load space compartment.</li> <li>Ensure vehicle driver is aware of the potential has the event of an accident or an emergency.</li> </ul>	
	Before transporting product containers:	
	<ul> <li>Ensure there is adequate ventilation.</li> <li>Ensure that containers are firmly secured.</li> </ul>	
	- Ensure valve is closed and not leaking.	
	- Ensure valve outlet cap nut or plug (where provi	
	<ul> <li>Ensure valve protection device (where provided</li> </ul>	I) is correctly fitted.

## SAFETY DATA SHEET

Page : 14/15 Revised edition no : 5.0

Revision date : 2024-02-02

Supersedes version of : 2023-01-21 **NOAL 0107** 

Country : SE / Language : EN

## Silane

14.7. Maritime transport in bulk according to IMO instruments

Not applicable.

SECTION 15: Regulatory information		
15.1. Safety, health and environmental regulations/legislation specific for the substance or mixture		
EU-Regulations		
Restrictions on use	: None.	
National legislation Seveso Directive : 2012/18/EU (Seveso III)	<ul><li>Ensure all national/local regulations are observed.</li><li>Covered.</li></ul>	
National regulations		
Ensure all national/local regulations are observed.		
Germany		
Water hazard class (WGK) National Rules and Recommendations	<ul> <li>WGK 1, Slightly hazardous to water (Classification according to AwSV)</li> <li>[German regulations] BetriebssicherheitsV mit TRBSen insbesondere TRBS 3145 / TRGS 725 Ortsbewegliche Druckgasbehälter", TRBS 2141, BGRegel 500 Teil 2.33: "Umgang mit Gasen", GefahrstoffV mit Technischen Regeln Gefährliche Stoffe TRGS insbesondere TRGS 407 "Tätigkeiten mit Gasen - Gefährdungsbeurteilung", TRGS 400, 500, 510, 900." BGR 104, TRBS 2152.</li> </ul>	
Netherlands		
SZW-lijst van kankerverwekkende stoffen	: The substance is not listed	
SZW-lijst van mutagene stoffen	: The substance is not listed	
SZW-lijst van reprotoxische stoffen – Borstvoeding	: The substance is not listed	
SZW-lijst van reprotoxische stoffen – Vruchtbaarheid	: The substance is not listed	
SZW-lijst van reprotoxische stoffen – Ontwikkeling	: The substance is not listed	
Denmark		
Danish National Regulations	: Young people below the age of 18 years are not allowed to use the product	
15.2. Chemical safety assessment		
	A CSA has been carried out.	

### **SECTION 16: Other information**

Indication of changes

: Safety data sheet in accordance with commission regulation (EU) No 2020/878.

Section	Changed item	Change	Comments
1.3	Company	Modified	Version 5.0. New address in Sweden. (This change only applies to the Swedish (SE) version of this SDS)

	SAFETY DATA SHEET	Page : 15/15			
<b>O</b> Air Liquide		Revised edition no : 5.0			
		Revision date : 2024-02-02			
		Supersedes version of : 2023-01-2			
	Silane	NOAL_0107			
		Country : SE / Language : EN			
Abbreviations and acronyms	REACH - Registration, Evaluation, Authorisation and I (EC) No 1907/2006 EINECS - European Inventory of Existing Commercial CAS# - Chemical Abstract Service number PPE - Personal Protection Equipment LC50 - Lethal Concentration to 50 % of a test populati RMM - Risk Management Measures PBT - Persistent, Bioaccumulative and Toxic vPvB - Very Persistent and Very Bioaccumulative STOT- SE : Specific Target Organ Toxicity - Single Ex CSA - Chemical Safety Assessment EN - European Standard UN - United Nations ADR - European Agreement concerning the Internation Road IATA - International Air Transport Association IMDG code - International Maritime Dangerous Good RID - Regulations concerning the International Carriag WGK - Water Hazard Class STOT - RE : Specific Target Organ Toxicity - Repeate UFI : Unique Formula Identifier	<ul> <li>CLP - Classification Labelling Packaging Regulation; Regulation (EC) No 1272/2008</li> <li>REACH - Registration, Evaluation, Authorisation and Restriction of Chemicals Regulation (EC) No 1907/2006</li> <li>EINECS - European Inventory of Existing Commercial Chemical Substances</li> <li>CAS# - Chemical Abstract Service number</li> <li>PPE - Personal Protection Equipment</li> <li>LC50 - Lethal Concentration to 50 % of a test population</li> <li>RMM - Risk Management Measures</li> <li>PBT - Persistent, Bioaccumulative and Toxic</li> <li>vPvB - Very Persistent and Very Bioaccumulative</li> <li>STOT - SE : Specific Target Organ Toxicity - Single Exposure</li> <li>CSA - Chemical Safety Assessment</li> <li>EN - European Agreement concerning the International Carriage of Dangerous Goods by Road</li> <li>IATA - International Air Transport Association</li> <li>IMDG code - International Maritime Dangerous Goods</li> <li>RID - Regulations concerning the International Carriage of Dangerous Goods by Rail</li> <li>WGK - Water Hazard Class</li> <li>STOT - RE : Specific Target Organ Toxicity - Repeated Exposure</li> <li>UFI : Unique Formula Identifier</li> </ul>			
Training advice	: Ensure operators understand the flammability hazard. Users of breathing apparatus must be trained. Ensure operators understand the toxicity hazard.				
Further information	<ul> <li>Classification in accordance with the procedures and (EC) 1272/2008 (CLP).</li> <li>Key literature references and sources of data are main</li> </ul>	-			

Full text of H- and EUH-statements	
Acute Tox. 4 (Inhalation:gas)	Acute toxicity (inhalation:gas) Category 4
Flam. Gas 1A	Flammable gases, Category 1A
H220	Extremely flammable gas.
H280	Contains gas under pressure; may explode if heated.
H332	Harmful if inhaled.
Press. Gas (Liq.)	Gases under pressure : Liquefied gas

### DISCLAIMER OF LIABILITY

Before using this product in any new process or experiment, a thorough material compatibility and safety study should be carried out.
 Details given in this document are believed to be correct at the time of going to press.
 Whilst proper care has been taken in the preparation of this document, no liability for injury or damage resulting from its use can be accepted.

#### End of document